

Addendum 1

City of Irving

ITB 023M-09F-09F
Demolition and Asbestos Abatement of Residential Structures,
Accessory Structures and Pool

The due date is changed from 3:00 p.m. on October 23, 2009 to **3:00 p.m. on October 28, 2009.**

This addendum is issued to make the following revision to this bid and is hereby incorporated and made a part of ITB Number 023M-10F

Q. Is it known if there is a septic tank on the property?

A. It is not known.

Q. At the Pre-Bid Site Visit we were told to remove the circular asphalt drive around the house and any asphalt within that area only, and to leave the driveway from the street. Also to remove a satellite dish that is not mentioned in the bid package. Is this correct?

A. 1st question: Yes that is correct

2nd question: Do not remove the satellite dish

Q. Contractors Responsibilities and Guidelines to Follow

Page 4 item 8. Will the existing fence around the perimeter of the property be sufficient to serve as a safety fence as required for this project?

A. Yes

Q. At the Pre-Bid the onsite representative of the city informed all who were present to remove the pool completely where as in the guidelines page 5 item 12 it states to punch holes in the bottom and to break off the coping three to four feet below grade and to use this material as backfill. Which of these does the city prefer?

A. **The pool needs to be completely removed**

Q. Is occupational accident insurance acceptable as a substitute for workers' comp?

A. No