

City of Irving

Local Effluent Discharge Limits

<u>Parameter</u>	<u>Collection Method</u>	<u>Maximum Allowable (mg/L)</u>
Arsenic	Composite	0.2
Cadmium	Composite	0.1
Chromium (total)	Composite	2.9
Copper	Composite	2.3
Cyanide (total)	Grab	0.5
Lead	Composite	0.9
Mercury	Composite	0.0004
Molybdenum	Composite	0.8 **
Nickel	Composite	4.6
Selenium	Composite	0.1
Silver	Composite	0.8
Zinc	Composite	8.0
Oil & Grease	Grab	200
TTO	Grab	2.13
pH (standard pH units)	Grab	5.5 min - 11.0 max.
*BOD5	Composite	250
*TSS	Composite	250

*For Surcharge only

** Effective 1-1-14